

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 2280-0289:100 Page 1 of 1

CATEGORY: Coating Material

LISTEE: Muralo, 148 E. 5th Street, Bayonne, NJ 07002
Contact: Frank Scanland *(323) 685-7220

DESIGN: MURALO 1500 WHITE interior fire retardant wall and ceiling finish. A latex flat white coating for Douglas fir lumber. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: UL label on each container.

APPROVAL: Listed as a coating material for use on Douglas fir lumber when applied at the rate specified on manufacturer's instructions. Approved for interior use only.

*Rev. 06-23-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager